

Central Water & Electric Utility Services

P.O. BOX 1409
 POLK CITY, FL 33868 US
 8637389215
 sjones7285@aol.com

Estimate

ADDRESS
 Blue Cypress mhp
 13801 US-441
 OKEECHOBEE, FL 34974

SHIP TO
 Blue Cypress mhp
 13801 US-441
 OKEECHOBEE, FL 34974

ESTIMATE # 1461 DATE 02/02/2022

SALES REP
 THARIN

DATE	ACTIVITY	DESCRIPTION	QTY	RATE	AMOUNT
	Repair & Maintenance	Repair & Maintenance Blue Cypress Water Treatment Plant PROBLEM: Existing control valve for the water storage tank and well controls is malfunctioning. At times the valve stays closed and will not provide water to the storage tank. Therefore, the storage tank runs low causing the high service pumps low level to shut off so as not to run the pumps dry. This intern leaves the system without water. Further, the water line has been reduced to accommodate the existing control valve from 4" to 3" then back up to 4" discharge after the valve. REMEDY: 1.) Remove existing control 3" control valve 2.) Furnish and install new 4"Electric valve 3.) Furnish and install new 4" butterfly valve 4.) Furnish and install new 4" piping and bypass for existing valve for maintenance purposes. 5.) Installation of well seal on tank 6.) Installation of ball float drop pipe s/o cord for control loop in tank 7.) PVC for installation of 4" fittings to return to automatic state. 8.) Installation of site tube for hydro	1	13,552.00	13,552.00

M. Jones
 2-22-22
 R.E.S. 2-23-22
 2-23-22

DATE	ACTIVITY	DESCRIPTION	QTY	RATE	AMOUNT
		tank			
		9.) Hour meter installation for each well			
		Start up and run.			
		Labor and Mobilization			
				TOTAL	\$13,552.00

Accepted By

Accepted Date